

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/18/02	10/16/02	31003	Private Property Owner	210 S Newhope St, Santa Ana, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to grease blockage. Approximately 200 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by private property owner.
10/23/02	10/23/02	31013	City of Huntington Beach	317 21St, Huntington Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to unknown blockage. 150 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Huntington Beach staff.
10/26/02	10/26/02	30999	City of Corona	Parkridge & Corona, Corona, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to grease blockage. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Corona staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/28/02	10/28/02	31002	City of Fullerton	Adlena & Bastanchury, Fullerton, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a manhole due to root blockage. All 600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up and disinfected by City of Fullerton staff.
10/29/02	10/29/02	31001	City of Corona	114 W 11th St, Corona, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to sewer line cave in. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by City of Corona staff.
11/3/02	11/3/02	31005	Private Property Owner	8925 Rockcreek Dr, Huntington Beach, Orange County	SSO	960	An estimated 960 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 50 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/3/02	11/3/02	31178	Private Property Owner	8945 Riverbend St, Huntington Beach, Orange County	SSO	950	An estimated 950 gallons of sewage overflow from a private apartment complex's lateral due to root blockage. None of the spill was contained or recovered. All 950 gallons of the spill were discharged into a local storm drain. The sewage comingled with waters in the channel, and entered into wetlands. The line was repaired and the blockage was cleared and the affected area was cleaned up by private property owner.
11/5/02	11/5/02	31004	City of Huntington Beach	21372 Brookhurst, Huntington Beach, Orange County	SSO	800	An estimated 800 gallons of sewage overflowed from a manhole due to grease blockage. 350 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by City of Huntington Beach staff.
11/5/02	11/5/02	31853	City of Huntington Beach	7232 Edinger, Huntington Beach, Orange County	SSO	551	An estimated 551 gallons of sewage overflowed from a private lateral due to construction debris (asphalt and concrete chunks). 100 gallons of the spill were contained, recovered, and returned to the sewer system. 451 gallons of the spill discharged into a local storm drain. Debris was removed and the blockage was cleared and the affected area was cleaned up by City of Huntington Beach staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/7/02	11/7/02	31851	City of Orange	125 W Rose at Glassell, Orange, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from an 8" gravity sewer line due to grease blockage. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. 500 gallons of the spill were not recovered and discharged into a local storm drain. The blockage was cleared and the affected area was cleaned up by City of Orange staff.
11/10/02	11/10/02	31009	Jurupa Community Services District	9017 63rd St, Pedley, Riverside County	SSO	750	An estimated 750 gallons of sewage overflowed from a manhole due to root blockage. All 750 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up and disinfected by JCSD staff.
11/11/02	11/11/02	31007	Orange County Sanitation District	5360 Kellogg Dr, Yorba Linda, Orange County	SSO	900	An estimated 900 gallons of sewage overflowed from a manhole due to unspecified blockage. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by OCSD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/11/02	11/11/02	31008	Private Property Owner	3642 Katella, Los Alamitos, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to unknown blockage. 300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by private property owner.
11/15/02	11/14/02	31022	Rubidoux Community Services District	4036 Briggs St, Rubidoux, Riverside County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to grease blockage. 1,300 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by Rubidoux Community Services District.
11/16/02	11/16/02	31021	Cucamonga County Water District	Main & Archibald, Rancho Cucamonga, San Bernardino County	SSO	5,000	An estimated 5,000 gallons of sewage overflowed from a manhole due to grease blockage. All 5,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up and disinfected by CCWD staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/19/02	11/19/02	31301	Costa Mesa Sanitary District	16th Street and Newport Blv. South Costa Mesa, Orange County	SSO	531	An estimated 531 gallons of sewage overflowed from a manhole due to grease and towels that blocked the District's main line. All 531 gallons of the spill were contained, recovered, and returned to the operational sewer system. The line was repaired and the blockage was cleared and the affected area was cleaned up by Costa Mesa Sanitary District staff.
11/21/02	11/21/02	31848	Private Property Owner	Saint Claires and Pennsylvania Ave., Lake Elsinore, Riverside County	SSO	8,850	An estimated 8,850 gallons of sewage overflow from a manhole due to road grading, when a developer dumped debris into manhole. 7,800 gallons of the spill were contained, recovered, and returned to operational sewer system. Debris was removed, the line was repaired and the affected area was cleaned up and disinfected by Elsinore Valley Municipal Water District staff.

Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
10/16/02	10/16/02	2803 ROYAL PALM DRIVE, COSTA MESA	COSTA MESA FIRE STATION #1	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
10/21/02	10/21/02	99 FAIR DRIVE, COSTA MESA	COSTA MESA POLICE DEPARTMENT	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
12/5/02	10/8/02	3125 ORANGETHORPE AVENUE, EAST, ANAHEIM	EQUILON ENTERPRISES LLC/SHELL OIL PRODUCTS U.S.	UNDERGROUND STORAGE TANK LEAK: WASTE OIL CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
12/5/02	10/28/02	22943 RIDGE ROUTE DRIVE, LAKE FOREST	CHEVRON STATION 9-0884	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
12/6/02	11/29/02	2700 SANTIAGO BOULEVARD, ORANGE	FORMER NOHL RANCH AUTO SPA	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
11/21/02	9/27/02	2099 STATE COLLEGE BLVD., S., ANAHEIM	STARWOOD O.C. PORTFOLIO VII, L.L.C.	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	POLLUTION CHARACTERIZATION
10/10/02	10/10/02	44462 E. FLORIDA, HEMET	WAHL'S SHELL	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED

*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger. This report may not contain an accurate listing of all the new cases due to the ongoing reconciliation between the Geotracker/GEIMS, DOD, and Local Agency databases.